

# Preliminary Assessment Report

## Project 3023025, 1915 3RD AVE

---

**Assessment Completed:** 12/11/2015

**Project Description:** EDG/SEPA - Renovation of existing 6 story building and new construction of 6 additional stories above existing building, including new mechanical, plumbing, electrical and drainage.

**Primary Applicant:** [Poppi Handy](#)

This report lists the results of a preliminary assessment of your project requirements by various city departments. It's based on the project characteristics described on your site plan and preliminary application form. If your project required a pre-application site visit (PASV), the results of that site visit are also included. The goal of this report is to help you create a complete submittal package and reduce the need for corrections once your application has been submitted.

### Next Steps

1. Review the requirements in this report and contact the staff members listed below with questions.
2. If a street improvement plan is required, develop and submit it to the Seattle Department of Transportation (SDOT). **The Department of Planning and Development (DPD) will not accept your permit application until your street improvement plan is approved as 60% complete by SDOT. See [SDOT Client Assistance Memo 2213](#) for guidance about the 60% complete approval process.**
3. Schedule an appointment for permit application intake with DPD. **Please bring a copy of this report to your intake appointment.**

### Questions About This Report

If you have questions about the information in this report, contact the appropriate city staff member for each section.

#### DPD Drainage Requirements

Eric Dripps, (206) 727-3676, [Eric.Dripps@seattle.gov](mailto:Eric.Dripps@seattle.gov)

#### DPD Land Use Requirements

Megan Neuman, (206) 684-3101, [Megan.Neuman@Seattle.gov](mailto:Megan.Neuman@Seattle.gov)

#### DPD Preapplication Site Visit Requirements

Keller Rockey, (206) 684-7914, [Keller.Rockey@seattle.gov](mailto:Keller.Rockey@seattle.gov)

#### Seattle City Light Requirements

Ray Ramos, (206) 615-1193, [ray.ramos@seattle.gov](mailto:ray.ramos@seattle.gov)

#### Seattle Department of Transportation Requirements

Yohannes Minas, (206) 733-9044, [yohannes.minas@seattle.gov](mailto:yohannes.minas@seattle.gov)

#### Seattle Public Utilities Requirements

Lan Chau, (206) 727-3584

### Other Resources

- General questions about the permit process: Contact the DPD Applicant Services Center (ASC) at 206-684-8850.
- User-friendly guides to city permitting processes: [DPD](#) and [SDOT](#).
- [Detailed zoning information](#).
- Visit our [permit type pages](#) for step-by-step instructions and forms for preparing your application and plans for review.

## Requirements

### **DPD Drainage Requirements**

The following requirements are based on the current stormwater and side sewer codes.

#### **Existing Public Drainage Infrastructure**

Combined sewer main location: 3rd Ave

Combined sewer main size: 12" Diameter

#### **Drainage**

The drainage point of discharge (SMC 22.805.020) is located at: Combined sewer.

**\*\*Alert\*\* Drainage requirements indicated in this Preliminary Assessment Report are per the 2009 Stormwater Code and Manual. The new 2016 Stormwater Code and Manual will become effective on January 1, 2016. The new rules will replace the current Stormwater Code and Directors' Rules. Projects with accepted applications on or after January 1, 2016 will be subject to the new 2016 Stormwater Code and Directors' Rules.**

#### **Flow Control Compliance**

All new, replaced, and disturbed topsoil shall be amended with organic matter per rules promulgated by the Director prior to completion of the project to improve onsite management of drainage water flow and water quality per SMC 22.805.020.E. A completed [Construction Stormwater Control and Soil Amendment Standard Plan](#) is required.

#### **Water Quality**

No requirements

#### **Permanent and Temporary Dewatering**

The footing drain (if part of building plan) point of discharge ([DPD DR 4-2011](#)) is located at the following: Combined system.

#### **Side Sewer**

The existing side sewer for a new or converted building or dwelling unit may be reused pursuant to SMC 21.16.240.

In order to reuse an existing side sewer, the [Side Sewer Evaluation and Certification Form](#) must be completed by a licensed engineer.

### **DPD Land Use Code Requirements**

#### **Street Requirements**

Based on the scope of the proposed project, the following street improvements are required per Chapter 23.53 of the Seattle Municipal Code. Please review Right-of-Way Improvements Manual for design criteria (<http://www.seattle.gov/transportation/rowmanual/manual/>). Show required street improvements on your "enhanced site plan" at DPD permit application intake. If an SDOT Street Improvement Plan (SIP) is required, please list SDOT project number and SDOT contact name on the enhanced site plan. Street Improvement Plans must be accepted by SDOT prior to DPD permit application intake.

#### **3RD AVE**

Street trees shall be provided in the planting strip according to Seattle Department of Transportation Tree Planting Standards. Contact SDOT Urban Forestry (for residential projects: (206) 684-TREE; for all others: (206) 684-5693), to determine species of tree and standards of planting. Please add a note to the site plan

showing size, location and species of tree to be planted.  
<http://www.seattle.gov/transportation/treeplanting.htm>.

Other requirements: 18 foot sidewalks required per Map IC for 23.49.

## **Alley Requirements**

### **ALLEY WEST OF SITE**

Pave the width of the alley abutting the lot and the portion of alley between the lot and the connecting street. The Seattle Right of Way Improvements Manual ([http://www.seattle.gov/transportation/stuse\\_docs.htm](http://www.seattle.gov/transportation/stuse_docs.htm)) contains design details.

A 2 foot dedication is required. Refer to SDOT CAM 2203. Please see [http://www.seattle.gov/transportation/stuse\\_docs.htm](http://www.seattle.gov/transportation/stuse_docs.htm).

Other requirements: Per SMC 23.54.030.F.1, when existing structures are located in the portion of the lot to be dedicated, that portion of the lot shall be exempt from dedication requirements. Please show the location of existing structures in relation to the alley on the site plan submitted as part of the application.

## **Land Use**

Based on the project scope. SEPA may be required. See DPD Director's Rule 12-2012 for more details (<http://web1.seattle.gov/dpd/dirrrulesviewer/>).

## **Pre-Application Site Visit (PASV) Requirements**

PASV report requirements may be subject to additions, changes, or modifications by the department. The purpose of the report is to alert the applicant that there may be unusual or complex site conditions that trigger requirements from the department regarding this project. **The applicant is responsible for providing all required documents at the intake appointment.** If you have questions about this report or the PASV process, please contact the DPD Site Development Team at (206) 684-8860.

**Note:** Any project application associated with the development site can utilize the results from this PASV if the application is accepted by DPD within 24 months of the above inspection date. After 24 months, the applicant must apply for another PASV. No extensions will be granted.

## **ECA Mapping Unit and Type**

Non-ECA

## **Existing ROW Conditions**

### **3RD AVE**

Street conditions:

Concrete paving

Visible pavement width is: 52

,

Curb conditions:

Curb adjacent to site

Approximate curb height: 6" inches

A storm inlet is located <350 ft from the site and prior to crossing a public right of way.

It appears that drainage from that discharge point will remain in the gutter line all the way to the nearest inlet structure, but this assessment is preliminary and it is the responsibility of the applicant to meet all relevant SW code requirements.

## **ALLEY WEST OF SITE**

Concrete paving

Downstream inlet prior to crossing sidewalk

Comments: Brick alley

## **Potential Impacts to Seattle Parks Property**

No parks property in vicinity

## **Tree Protection**

Existing trees appear to be shown accurately on the site plan

## **Construction Stormwater Control**

All projects with earth disturbance, regardless of size, require temporary and permanent stormwater control in accordance with the Construction Stormwater Control (CSC) Technical Requirements Manual ([DR 16-2009, Volume 2](#)).

**Show the following on the [Construction Stormwater Control and Soil Amendment Standard Plan](#):**

Place compost socks, compost berms, filter fabric fencing, straw bales, straw wattles, or other approved perimeter control BMPs to eliminate construction stormwater runoff.

Show the location of a stabilized construction access to the site; show methods to eliminate uncontrolled conveyance of mud and dirt into the right of way (ROW).

Place silt-trapping inserts in receiving catch basins located within 10 feet of construction entrance.

Cover bare soil with compost blankets, straw, mulch, matting, or other approved equal to control construction stormwater runoff.

Cover stockpiles and bare slopes with compost blankets, tarps, matting or other approved equal to control construction stormwater runoff.

A First Ground Disturbance inspection is required before any ground disturbance related to this permit, including demolition, tree cutting, clearing, grubbing, and grading. After your permit is issued, schedule an inspection by calling (206) 684-8900 or [online](http://web1.seattle.gov/DPD/InspectionRequest/default.aspx) at <http://web1.seattle.gov/DPD/InspectionRequest/default.aspx>.

## **Seattle City Light Requirements**

### **Street/Alley Requirements**

#### **3RD AVE**

Underground electrical facilities/conductors require separation from other utilities. Review City Light Construction Standard 0214.00, Clearances Between SCL Underground Structures and Other Utility Structures in the Public Right-of-Way (<http://www.seattle.gov/Light/engstd/>). Before digging, contact the Utilities Underground Location Center ("one-call") at (800) 424-5555 two business days in advance to locate and mark underground utilities, per state law (RCW 19.122). There are underground electrical lines for streetlighting along 3rd Ave.

#### **ALLEY WEST OF SITE**

Underground electrical facilities/conductors require separation from other utilities. Review City Light Construction Standard 0214.00, Clearances Between SCL Underground Structures and Other Utility Structures in the Public Right-of-Way (<http://www.seattle.gov/Light/engstd/>). Before digging, contact the Utilities Underground Location Center ("one-call") at (800) 424-5555 two business days in advance to locate and mark underground utilities, per state law (RCW 19.122). There are underground high voltage lines and electrical facilities along the alley.

Your project is located in a Seattle City Light Network area. Based on our assessment of the size of your project, you may need transformers on your private property for power service to your building. This can be done with vaults inside the building or below grade vaults exterior to the building. Include these facilities for your project power needs in your building plans. SCL has access, clearance, size and location requirements for vaults or pads. Some transformers require long lead times to obtain. Contact SCL well in advance to provide electrical service service size and voltage details.

### **Notes to Applicant**

For a new or revised electrical service, please contact the Electrical Service Representative for your area several months before new service is required to determine your electric service design, service location and what kind of service is available at the building site. An Application for Electrical Service must be submitted to Seattle City Light. The Electrical Service Representative should also be contacted to coordinate electrical disconnections prior to demolition and temporary power for construction. Your Electrical Service Representative is: Richard Ohashi, 206-386-1674, [richard.ohashi@seattle.gov](mailto:richard.ohashi@seattle.gov). Be advised that it is the applicant's responsibility to seek guidance from City Light. Failure to contact City Light early in the permit process could severely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

## **SDOT Requirements**

The City of Seattle's Right-of-Way Improvements Manual (ROWIM) and SDOT's Street & Sidewalk Pavement Opening and Restoration (PORR) Director's Rule 2004-02 may be accessed from SDOT's Street Use website at: [http://www.seattle.gov/transportation/stuse\\_docs.htm](http://www.seattle.gov/transportation/stuse_docs.htm). Whenever possible, specific reference notation for these two design documents is noted next to the design characteristics below. Be advised that these specific section and chapter references are provided as preliminary guidance only and are not comprehensive in scope.

### **SDOT Permitting Information**

SDOT Plan Requirements: Plan

SDOT Permit Requirements: Group 2: Over-the-Counter. Obtain from SDOT concurrently with building permit.

Based on the scope of your project and the proximity to the lot line a SIP may be triggered by the extent of construction impacts to existing street, sidewalk or alley improvements. If more than 2,000 sf of impervious surface in the right of way will be replaced a SIP will be required.

A drainage review is required as part of the Street Use Permit if more than 750 square feet of land disturbing activity will take place in the right of way.

### **Alley Requirements**

#### **ALLEY WEST OF SITE**

Other requirements: Pave width of alley to be dedicated.

## **SPU Requirements**

### **Flow Control Compliance**

All new, replaced, and disturbed topsoil shall be amended with organic matter per rules promulgated by the Director prior to completion of the project to improve onsite management of drainage water flow and water quality per SMC 22.805.020.E. For projects with 5,000 square feet or more of new and replaced impervious surface, a comprehensive drainage control plan shall be prepared by a licensed engineer.

### **Solid Waste**

Your project is fronted by a major arterial. An alternate location for pickup of your solid waste is required. For questions about solid waste requirements, contact Liz Kain, (206) 684-4166, [Liz.Kain@seattle.gov](mailto:Liz.Kain@seattle.gov) and see CAM 1301; [Solid Waste: Information for Developers](#).

For all multifamily, commercial, and industrial properties, the requirements for solid waste storage and pickup are outlined in SPU CAM 1301, available on the web at:

[http://www.seattle.gov/util/stellent/groups/public/@spu/@csb/documents/webcontent/cos\\_004542.pdf](http://www.seattle.gov/util/stellent/groups/public/@spu/@csb/documents/webcontent/cos_004542.pdf). For questions about solid waste requirements, contact Liz Kain, (206) 684-4166, [Liz.Kain@seattle.gov](mailto:Liz.Kain@seattle.gov).

## **Other Requirements**

Owners of residential property occupied by a tenant who will be displaced by housing demolition, substantial rehabilitation, change of use, or removal of use restrictions may need to obtain a Tenant Relocation License. Refer to DPD Tip 123, Seattle's Tenant Relocation Assistance Ordinance, for further information and instructions or call (206) 684-7979.

If your project involves additions or modification to or demolition of an existing building that contains four or more dwelling units or 4,000 square feet or more of non-residential area, and the building is a designated historic landmark or is 50 years old and meets the criteria set forth in SMC 25.12 for landmark designation, SEPA is required. Please contact the Department of Neighborhoods at (206) 684-0228 or [www.seattle.gov/neighborhoods/preservation](http://www.seattle.gov/neighborhoods/preservation) to determine if your building is a designated landmark or if a referral is necessary to determine if the building meets the criteria in SMC 25.12. Refer to Tip 208 for information regarding the application requirements for a SEPA review and Tip 3000 for information regarding landmarks and historic preservation.

If the scope of your proposed project changes before your DPD intake appointment or SDOT street improvement plan application, the requirements in this report may change. If there are municipal code and ordinance changes before our DPD intake appointment, the project must meet the new code requirements. Additional street improvement requirements may be triggered if a permit application for a development project on adjacent property is also undergoing review.

Please be aware that all persons or companies working within the City limits, including all contractors, subcontractors, permit expeditors and other service providers are required to possess a valid City of Seattle business license. This license is required in addition to any other licenses required by the State of Washington, such as a contractors' license or state business license. For more information about City of Seattle business licenses, please contact inspector Michale Crooks at 206-684-8871, [Michale.Crooks@seattle.gov](mailto:Michale.Crooks@seattle.gov), or visit the [Licensing and Tax Administration Division website](#).